

~~CONFIDENTIAL~~

25X1A6c

Chief, Real Estate and Construction Division, OL

9-2-28
6 March 1959

Chief, Engineering Staff, OC

Building Changes to Communications Area - [REDACTED]

25X1A6a

25X1C4a

1. The following features should be incorporated into the space allocated in the [REDACTED] building for the communication facilities. The area in question is designated as a File Room on the third floor of the building.

- a. Walls and ceiling acoustically tiled.
- b. Steel backed entrance door with a 3-way M/P lock.
- c. Adequate overhead incandescent lighting.
- d. At least four standard convenience outlets.
- e. A 2-inch plastic conduit from the File Room to the roof through the adjacent elevator shaft.
- f. A 2-inch metal conduit from the File Room to the roof through the adjacent elevator shaft.
- g. A metal conduit with two No. 8 AWG conductors from the nearest 115 VAC, 30 Amp. source to a utility box mounted on the File Room nearest the elevator shaft.
- h. A metal conduit with two No. 10 AWG conductors from the emergency generator pad to the utility box in the File Room.
- i. A single conductor No. 6 AWG ground wire from the water service entrance to the utility box in the File Room.
- j. A generator mounting pad near the corner of the terrace adjacent to the office designated Political "A", two assistants. A distance of at least three feet should be maintained between this pad and the adjacent wall and railing.
- k. A waterproof generator enclosure.

see drawing

NOTE: Items (e) through (k) above appear on the attached drawing.

Document No. 3	No Change in Class. <input checked="" type="checkbox"/>	Class. Changed To: TS S G	By: ZC
	Declassified <input type="checkbox"/>	Auth: HR 70-2	
	Date: 7 NOV 1978		

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~

SUBJECT: Building Changes to Communications Area - [REDACTED]

25X1A6a

2. It is requested that immediate action be taken with the [REDACTED] to have these modifications included in the new building. 25X1C4a

3. If further details are required, please contact [REDACTED] extension 2936.

25X1A9a

for

25X1A9a

Attachment:

Drawing No. C5411.20-S-02 - 3 each

Distribution:

Original + 1 - Addressee, w/attach.

~~CONFIDENTIAL~~

MISSING PAGE

ORIGINAL DOCUMENT MISSING PAGE(S):

missing attachment